



PORTABLE APPLIANCE TESTING

24 Old Road  
Coggeshall  
Essex  
CO6 1RS

## Patpass Limited Risk Assessment for Pat Testing

Hazard	Who's at Risk	Preventative Actions
Electric Shock	Test Technician	<ol style="list-style-type: none"><li>1) Fully isolate all items for testing</li><li>2) Compliance is followed in test sequences as outlined in the IEE code of practice.</li><li>3) Test Equipment is specifically designed to minimise the risk of Electric Shock by the removal of fault paths to earth.</li></ol>
Poor condition of Appliances	Test Technician All users of such equipment	Technicians will carry out a full visual inspection to ensure no damage is present Exposing internal electrical components – Remove from service will be advised to Client if required the appliance will be Labelled Dangerous Do Not Use.
Working in Confined Spaces under desks		Technicians will ensure that all people in surrounding areas are aware of his Presence and the need for him to work under desks, (out of sight).
Testing on Site		Technicians will always carry 6 Part Personal Protective Equipment. Comprising Of the following; Hard Hat Safety Boots High Viz Clothing Safety Goggles Site Gloves Safety Mask